## **Product Specification Sheet**





## 50kW LT Fan Coil

Able to be installed with floor, racking or ceiling mounts, the 50kW LT Fan Coil unit is capable of maintaining sub 4°C temperatures in a chilled storage environment, providing an impressive airflow of up to 18,6720m3/hr. These units are ideal for use with food and distribution businesses either looking to expand their cooled storage capacity or needing a temporary cooling replacement whilst upgrading their permanent equipment, ensuring no loss in temperature control.

The 50kW LT Fan Coil unit are backed by a remote thermostatic control which can be set in 1°C intervals through a remote temperature monitored interface. All fans coils are supplied with a 3-way valve and defrost controls, allowing safe management of the unit temperature by way of a linked temperature probe. Available to hire on a single unit or multi-unit basis with a quick and easy install process. Each unit can be easily connected to one of our Hire Chiller Units or to the customers own chilled glycol system, ready for immediate use.

19-04-2025 | 13:55:57



E-mail: info@elbjorn.com

## **Product Benefits**

- Simple to use digital controller
- Stackable steel frame for ease of positioning and installation
- Integral electric defrost elements on cooling coil and within the condense drip tray
- Ideal for cold storage applications for foods, beverages, poultry among others

## **Technical Data**

Product name	50kW LT Fan Coil
Product Number	GB83051H
Cooling capacity (kW)	50
Air temperature in	+4.0 °C
Air temperature out	0 °C
Coolant	MP-glycol @ 30% / Water
Coolant temperature in/out	-8.0 / -4.2 °C
Volume Flow (m³/h)	11.96
No. of fans	2
Fan diameter	630 mm
Air Flow (m3/h)	18 720
Air throw	25 m
Power supply	400v 3ph 50Hz +E (no neutral)
Plug type	32a 3ph 5pin

19-04-2025 | 13:55:57



Max running current (Defrost mode)	24.71 Amps/Phase
Max running current (Fan mode)	1.3 Amps/Phase
Dimension L/W/H (mm)	3370 x 1200 x 1580
Weight (Empty with frame) (kg)	876
Weight (Empty without frame) (kg)	526

19-04-2025 | 13:55:57

